



NOTES:

1. ALL DIMENSION IN METERS.(UNLESS NOTED)
2. DITCH ELEVATION TO BE AT OR BELOW SUBGRADE ELEVATION.
3. MINIMUM DEPTH OF COVER
 

STORM SEWER	1.50m
SANITARY SEWER	2.80m
WATERMAIN	2.00m
GAS MAIN	0.75m IN BLVD.
HYDRO/BELL/CABLE	1.00m IN BLVD.
3. THE FOLLOWING IS A MINIMUM ROAD BASE AND WILL REQUIRE A SOILS REPORT VERIFICATIONS TO DERMINE IF ADDITIONAL THICKNESS IS REQUIRED.
 

40mm HL4
60mm HL8
150mm GRANULAR 'A'
450mm GRANULAR 'B'
4. MINIMUM CULVERT SIZE 450mm DIAMETER.

20.0m RURAL ROAD ROW



TOWNSHIP OF WILMOT

PUBLIC WORKS AND ENGINEERING DEPARTMENT

DATE: MARCH 2022

SCALE: N.T.S.

DWG No.: WIL-DET-22-34

REV: 0